

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.6	29.5			Y
2	7.6	29.0			Y
3	7.6	30.0			Y
4	7.6	29.5			Y
5	7.6	33.0			Y
6	7.6	32.0			Y
7	7.6	31.0			Y
8	7.6	31.3			Y
9	7.6	31.5			Y
10	7.7	31.6			Y
11	7.6	30.5			Y
12	7.7	30.0			Y
13	7.6	31.0			Y
14	7.7	30.5			Y
15	7.5	28.9			Y
16	7.6	30.0			Y
17	7.6	32.0			Y
18	7.7	30.0			Y
19	7.8	29.0			Y
20	7.8	28.5			Y
21	7.8	32.5			Y
22	7.8	32.0			Y
23	7.7	31.5			Y
24	7.7	31.2			Y
25	7.7	31.2			Y
26	7.6	33.0			Y
27	7.6	29.0			Y
28	7.6	28.0			Y
29	7.6	28.1			Y
30	7.6	25.0			Y
31	7.6	31.5			Y

<< Have minimums been met for this day

ENTRY POINT

A

PWS ID 4100591

OREGON CITY - SOUTH FORK W B

Sample Period: October 2021

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 1
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)


Is system in compliance? Y

Reference

Minimum Water Quality Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Katelynn Niece

Signature: 

Date: November 1, 2021

Phone #: 503-657-5030

(No = N = Excursion) Total N's 0