

**OHA Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.6	26.9	/	/	Y
2	7.5	25.0	/	/	Y
3	7.8	31.0	/	/	Y
4	7.8	27.5	/	/	Y
5	7.7	29.1	/	/	Y
6	7.6	26.5	/	/	Y
7	7.6	26.0	/	/	Y
8	7.5	24.4	/	/	Y
9	7.6	25.5	/	/	Y
10	7.6	25.0	/	/	Y
11	7.6	26.0	/	/	Y
12	7.5	19.5	/	/	N
13	7.7	20.8	/	/	Y
14	7.6	18.2	/	/	N
15	7.6	22.0	/	/	Y
16	7.6	23.5	/	/	Y
17	7.5	23.0	/	/	Y
18	7.9	26.0	/	/	Y
19	7.9	24.5	/	/	Y
20	7.8	23.5	/	/	Y
21	7.8	24.6	/	/	Y
22	7.6	22.2	/	/	Y
23	7.6	26.5	/	/	Y
24	7.8	25.5	/	/	Y
25	7.6	26.0	/	/	Y
26	7.7	25.5	/	/	Y
27	7.7	24.0	/	/	Y
28	7.7	24.8	/	/	Y
29	7.5	25.5	/	/	Y
30	7.5	26.4	/	/	Y
<b>(No = N = Excursion) Total N's</b>					<b>2</b>

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
<b>Sample Period:</b> <u>November 2021</u>
Month/Year

**Number of excursions\* during this month:** 2  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during previous 5 months:** 1  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?** Y

<b>Reference</b>	
Minimum Water Quality Parameters as set by State:	
pH <table border="1"><tr><td>7.5</td></tr></table>	7.5
7.5	
Alk <table border="1"><tr><td>20.0</td></tr></table>	20.0
20.0	

**Print Name:** Katelynn Niece

**Signature :** *Katelynn Niece*

**Date:** December 1, 2021

**Phone #** 503-657-5030