

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.5	23.5			Y
2	7.6	24.0			Y
3	7.6	23.5			Y
4	7.7	23.5			Y
5	7.8	24.5			Y
6	7.7	25.8			Y
7	7.6	24.5			Y
8	7.6	25.0			Y
9	7.6	22.5			Y
10	7.6	24.8			Y
11	7.7	22.5			Y
12	7.7	28.5			Y
13	7.7	22.9			Y
14	7.6	23.5			Y
15	7.6	24.0			Y
16	7.6	25.5			Y
17	7.9	26.0			Y
18	7.8	25.0			Y
19	7.8	24.0			Y
20	7.9	24.6			Y
21	7.5	22.0			Y
22	7.6	23.0			Y
23	7.7	22.0			Y
24	7.8	22.5			Y
25	7.8	23.5			Y
26	7.8	21.5			Y
27	8.0	27.0			Y
28	7.8	23.0			Y
29	7.6	24.0			Y
30	7.7	26.0			Y
31	7.9	25.5			Y

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>December 2021</u>
Month/Year


Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Katelynn Niece

Signature: 

Date: January 3, 2022

Phone # 503-657-5030

(No = N = Excursion) Total N's 0