

**OHA Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.9	25.1			Y
2	8.1	27.0			Y
3	7.6	26.0			Y
4	7.7	24.5			Y
5	7.8	24.0			Y
6	7.7	22.0			Y
7	7.6	22.0			Y
8	7.8	21.5			Y
9	7.8	22.0			Y
10	7.8	26.6			Y
11	7.8	24.0			Y
12	8.0	24.5			Y
13	7.9	26.0			Y
14	7.9	23.5			Y
15	7.9	25.0			Y
16	7.7	24.5			Y
17	7.9	26.5			Y
18	7.8	24.0			Y
19	7.8	24.6			Y
20	7.8	22.0			Y
21	7.8	22.5			Y
22	7.9	22.0			Y
23	7.9	23.0			Y
24	7.8	23.2			Y
25	8.1	25.1			Y
26	7.9	24.5			Y
27	8.0	23.4			Y
28	8.2	25.5			Y
29	8.1	25.5			Y
30	7.9	25.0			Y
31	7.7	24.0			Y
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
Sample Period: <u>January 2022</u>
Month/Year


Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 2  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

<b>Reference</b>	
Minimum Water Quality Parameters as set by State:	
pH <table border="1"><tr><td>7.5</td></tr></table>	7.5
7.5	
Alk <table border="1"><tr><td>20.0</td></tr></table>	20.0
20.0	

Print Name: Katelynn Niece

Signature: 

Date: February 1, 2022

Phone #: 503-657-5030