

OHA Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8	24.0	/	/	Y
2	7.8	25.0	/	/	Y
3	7.6	27.0	/	/	Y
4	7.9	28.0	/	/	Y
5	7.9	25.0	/	/	Y
6	8.0	26.0	/	/	Y
7	7.8	25.0	/	/	Y
8	7.9	25.0	/	/	Y
9	7.9	23.0	/	/	Y
10	7.8	25.0	/	/	Y
11	8.0	25.0	/	/	Y
12	8.1	25.5	/	/	Y
13	8.2	25.5	/	/	Y
14	7.9	24.5	/	/	Y
15	7.8	25.0	/	/	Y
16	7.7	25.0	/	/	Y
17	8.0	25.0	/	/	Y
18	8.1	27.5	/	/	Y
19	8.2	24.0	/	/	Y
20	8.2	25.5	/	/	Y
21	7.9	24.5	/	/	Y
22	8.1	24.5	/	/	Y
23	7.9	25.0	/	/	Y
24	7.7	28.0	/	/	Y
25	8.1	27.0	/	/	Y
26	8.3	30.0	/	/	Y
27	8.0	25.5	/	/	Y
28	7.8	24.0	/	/	Y

<< Have minimums been met for this day

ENTRY POINT

A

PWS ID 4100591

OREGON CITY - SOUTH FORK W B

Sample Period: February 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)


Is system in compliance? Y

Reference

Minimum Water Quality
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Katelynn Niece

Signature: 

Date: March 1, 2022

Phone #: 503-657-5030

(No = N = Excursion) Total N's 0