

**OHA Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.5	22.0			Y
2	7.5	21.0			Y
3	7.8	21.0			Y
4	7.7	20.0			Y
5	7.8	22.5			Y
6	7.7	20.0			Y
7	7.6	23.0			Y
8	7.6	22.7			Y
9	7.7	23.2			Y
10	7.7	23.0			Y
11	7.8	23.5			Y
12	7.8	23.0			Y
13	7.9	22.5			Y
14	7.7	23.5			Y
15	7.8	26.0			Y
16	7.6	24.0			Y
17	7.7	22.0			Y
18	7.7	22.0			Y
19	7.7	24.0			Y
20	7.8	22.5			Y
21	7.7	23.1			Y
22	7.7	24.0			Y
23	7.7	22.0			Y
24	7.8	22.5			Y
25	7.7	21.0			Y
26	7.9	21.0			Y
27	7.9	20.0			Y
28	7.7	21.0			Y
29	7.6	22.0			Y
30	7.5	24.0			Y
31	7.6	22.0			Y

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
<b>Sample Period:</b> <u>March 2022</u>
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)


**Total excursions during previous 5 months:** 2  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?** Y

<b>Reference</b>
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

(No = N = Excursion) Total N's 0

**Print Name:** Katelynn Niece

**Signature :** 

**Date:** April 5, 2022

**Phone #** 503-657-5030