

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.9	23.5	/	/	Y
2	7.8	22.0	/	/	Y
3	7.9	23.0	/	/	Y
4	7.8	24.0	/	/	Y
5	7.7	23.0	/	/	Y
6	7.7	21.0	/	/	Y
7	7.6	21.0	/	/	Y
8	7.8	21.0	/	/	Y
9	7.8	22.0	/	/	Y
10	7.7	25.0	/	/	Y
11	7.7	23.0	/	/	Y
12	7.5	22.0	/	/	Y
13	7.5	22.5	/	/	Y
14	7.6	23.0	/	/	Y
15	7.9	21.5	/	/	Y
16	7.8	23.5	/	/	Y
17	7.9	22.5	/	/	Y
18	7.6	23.5	/	/	Y
19	7.6	22.5	/	/	Y
20	7.5	22.5	/	/	Y
21	7.5	23.5	/	/	Y
22	7.7	25.5	/	/	Y
23	8.0	24.0	/	/	Y
24	8.0	23.5	/	/	Y
25	7.9	24.0	/	/	Y
26	7.7	23.5	/	/	Y
27	7.7	23.0	/	/	Y
28	7.7	23.0	/	/	Y
29	7.9	26.0	/	/	Y
30	8.0	24.0	/	/	Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

<p>ENTRY POINT A PWS ID 4100591 OREGON CITY - SOUTH FORK W B Sample Period: <u>April 2022</u> Month/Year</p>
--

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Katelynn Niece

Signature: *Katelynn Niece*

Date: May 2, 2022

Phone #: 503-657-5030