

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.9	22.5	/	/	Y
2	7.7	22.0	/	/	Y
3	7.7	23.0	/	/	Y
4	7.6	24.0	/	/	Y
5	7.7	21.5	/	/	Y
6	7.7	21.5	/	/	Y
7	7.7	21.0	/	/	Y
8	7.7	20.5	/	/	Y
9	7.7	20.5	/	/	Y
10	7.6	20.0	/	/	Y
11	7.6	23.0	/	/	Y
12	7.6	23.5	/	/	Y
13	7.8	22.4	/	/	Y
14	7.7	23.1	/	/	Y
15	7.6	22.1	/	/	Y
16	7.9	22.5	/	/	Y
17	7.6	21.0	/	/	Y
18	7.7	20.5	/	/	Y
19	7.6	20.5	/	/	Y
20	7.7	20.2	/	/	Y
21	7.8	24.6	/	/	Y
22	7.8	22.1	/	/	Y
23	8.0	24.5	/	/	Y
24	7.8	23.0	/	/	Y
25	8.1	23.5	/	/	Y
26	7.8	24.0	/	/	Y
27	8.0	25.0	/	/	Y
28	7.9	21.5	/	/	Y
29	7.8	22.5	/	/	Y
30	7.7	20.5	/	/	Y
31	7.5	22.2	/	/	Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

<p>ENTRY POINT A PWS ID 4100591 OREGON CITY - SOUTH FORK W B Sample Period: <u> May 2022 </u> Month/Year</p>
--

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

<p>Reference Minimum Water Quality Parameters as set by State:</p> <table border="1"> <tr> <td>pH</td> <td align="center">7.5</td> </tr> <tr> <td>Alk</td> <td align="center">20.0</td> </tr> </table>	pH	7.5	Alk	20.0
pH	7.5			
Alk	20.0			

Print Name: Katelynn Niece
Signature: *Katelynn Niece*
Date: June 1, 2022
Phone #: 503-657-5030