

OHA Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6	20.3	/	/	Y
2	7.6	23.7	/	/	Y
3	7.8	23.0	/	/	Y
4	7.8	21.5	/	/	Y
5	7.8	23.0	/	/	Y
6	7.9	24.3	/	/	Y
7	7.8	22.5	/	/	Y
8	7.8	20.6	/	/	Y
9	7.6	21.4	/	/	Y
10	7.7	23.0	/	/	Y
11	7.6	21.0	/	/	Y
12	7.6	20.0	/	/	Y
13	7.8	21.0	/	/	Y
14	7.8	20.3	/	/	Y
15	7.7	21.3	/	/	Y
16	7.8	24.7	/	/	Y
17	7.7	23.4	/	/	Y
18	7.7	22.8	/	/	Y
19	7.7	23.1	/	/	Y
20	7.7	22.2	/	/	Y
21	7.8	22.7	/	/	Y
22	7.8	23.2	/	/	Y
23	7.7	25.0	/	/	Y
24	7.7	23.9	/	/	Y
25	7.8	24.0	/	/	Y
26	7.8	24.5	/	/	Y
27	7.7	25.5	/	/	Y
28	7.7	24.7	/	/	Y
29	7.7	24.6	/	/	Y
30	7.7	24.0	/	/	Y
			/	/	Y

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: June 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference

Minimum Water Quality
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Katelynn Niece
Signature: *Katelynn Niece*
Date: July 5, 2022
Phone #: 503-657-5030

(No = N = Excursion) Total N's 0