

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.7	27.5	/	/	Y
2	7.6	25.0	/	/	Y
3	7.7	27.5	/	/	Y
4	7.5	27.5	/	/	Y
5	7.6	26.4	/	/	Y
6	7.8	25.0	/	/	Y
7	7.6	28.0	/	/	Y
8	7.7	24.5	/	/	Y
9	7.7	29.0	/	/	Y
10	7.7	28.5	/	/	Y
11	7.7	24.5	/	/	Y
12	7.5	26.5	/	/	Y
13	7.6	26.4	/	/	Y
14	7.7	31.8	/	/	Y
15	7.6	28.0	/	/	Y
16	7.7	28.5	/	/	Y
17	7.5	27.5	/	/	Y
18	7.6	26.8	/	/	Y
19	7.6	29.6	/	/	Y
20	7.7	30.7	/	/	Y
21	7.6	29.5	/	/	Y
22	7.6	28.5	/	/	Y
23	7.6	29.5	/	/	Y
24	7.6	28.0	/	/	Y
25	7.6	31.6	/	/	Y
26	7.7	30.8	/	/	Y
27	7.7	30.5	/	/	Y
28	7.5	30.0	/	/	Y
29	7.5	29.0	/	/	Y
30	7.6	28.0	/	/	Y
31	7.6	29.5	/	/	Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>July 2022</u>
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Katelynn Niece
Signature: *Katelynn Niece*
Date: August 1, 2022
Phone #: 503-657-5030