

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.6	28.9	/	/	Y
2	7.6	30.0	/	/	Y
3	7.6	31.2	/	/	Y
4	7.7	31.0	/	/	Y
5	7.6	30.0	/	/	Y
6	7.6	30.5	/	/	Y
7	7.6	30.5	/	/	Y
8	7.6	36.0	/	/	Y
9	7.6	32.6	/	/	Y
10	7.6	31.0	/	/	Y
11	7.6	30.5	/	/	Y
12	7.6	30.0	/	/	Y
13	7.6	30.5	/	/	Y
14	7.7	31.0	/	/	Y
15	7.5	33.0	/	/	Y
16	7.7	30.8	/	/	Y
17	7.5	30.2	/	/	Y
18	7.5	34.5	/	/	Y
19	7.6	34.0	/	/	Y
20	7.6	32.0	/	/	Y
21	7.6	32.5	/	/	Y
22	7.6	30.5	/	/	Y
23	7.7	32.1	/	/	Y
24	7.5	29.1	/	/	Y
25	7.5	31.6	/	/	Y
26	7.6	32.5	/	/	Y
27	7.7	31.5	/	/	Y
28	7.6	30.0	/	/	Y
29	7.5	32.5	/	/	Y
30	7.6	31.0	/	/	Y
31	7.6	30.9	/	/	Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

<p>ENTRY POINT</p> <p>A</p> <p>PWS ID 4100591</p> <p>OREGON CITY - SOUTH FORK W B</p> <p>Sample Period: <u>August 2022</u></p> <p align="right">Month/Year</p>
--

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Katelynn Niece

Signature: *Katelynn Niece*

Date: September 1, 2022

Phone #: 503-657-5030