

## OHA Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6	33.2	/	/	Y
2	7.6	32.5	/	/	Y
3	7.6	31.5	/	/	Y
4	7.6	32.0	/	/	Y
5	7.6	32.0	/	/	Y
6	7.5	31.8	/	/	Y
7	7.7	31.2	/	/	Y
8	7.6	32.0	/	/	Y
9	7.6	30.5	/	/	Y
10	7.6	31.5	/	/	Y
11	7.6	32.0	/	/	Y
12	7.6	30.1	/	/	Y
13	7.5	32.2	/	/	Y
14	7.5	33.5	/	/	Y
15	7.6	33.3	/	/	Y
16	7.6	32.0	/	/	Y
17	7.6	30.5	/	/	Y
18	7.5	30.0	/	/	Y
19	7.6	32.3	/	/	Y
20	7.5	34.5	/	/	Y
21	7.5	32.0	/	/	Y
22	7.5	31.3	/	/	Y
23	7.6	31.0	/	/	Y
24	7.6	31.5	/	/	Y
25	7.6	30.5	/	/	Y
26	7.6	31.1	/	/	Y
27	7.5	31.4	/	/	Y
28	7.5	30.4	/	/	Y
29	7.4	33.2	/	/	N
30	7.5	33.5	/	/	Y
					Y
<b>(No = N = Excursion) Total N's</b>					1

<< Have minimums been met for this day

**ENTRY POINT**  
**A**  
**PWS ID 4100591**  
**OREGON CITY - SOUTH FORK W B**  
Sample Period: September 2022  
Month/Year

Number of excursions\* during this month: 1  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

**Reference**

Minimum Water Quality  
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Katelynn Niece

Signature: *Katelynn Niece*

Date: October 3, 2022

Phone #: 503-657-5030