

**OHA Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.5	31.9			Y
2	7.6	34.7			Y
3	7.6	32.3			Y
4	7.5	31.5			Y
5	7.6	34.2			Y
6	7.6	32.9			Y
7	7.5	30.4			Y
8	7.5	32.8			Y
9	7.5	32.0			Y
10	7.6	28.3			Y
11	7.6	32.6			Y
12	7.5	32.2			Y
13	7.6	29.9			Y
14	7.6	31.1			Y
15	7.5	31.5			Y
16	7.5	32.0			Y
17	7.6	31.3			Y
18	7.6	33.2			Y
19	7.5	32.5			Y
20	7.6	32.4			Y
21	7.5	34.1			Y
22	7.5	31.0			Y
23	7.5	30.0			Y
24	7.5	31.2			Y
25	7.5	44.5			Y
26	7.5	45.4			Y
27	7.7	49.1			Y
28	7.5	27.0			Y
29	7.6	30.7			Y
30	7.6	30.1			Y
31	7.5	32.3			Y
<b>(No = N = Excursion) Total N's</b>					0

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
<b>Sample Period:</b> <u>October 2022</u>
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during previous 5 months:** 1  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?** Y

<b>Reference</b>
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

**Print Name:** Katelynn Niece

**Signature:** Katelynn Niece

**Date:** November 1, 2022

**Phone #** 503-657-5030