

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.8	21.0	/	/	Y
2	7.9	21.4	/	/	Y
3	7.6	21.3	/	/	Y
4	7.6	21.3	/	/	Y
5	7.7	21.5	/	/	Y
6	7.6	23.9	/	/	Y
7	7.7	23.8	/	/	Y
8	7.6	22.8	/	/	Y
9	7.7	25.6	/	/	Y
10	7.6	22.8	/	/	Y
11	7.6	24.0	/	/	Y
12	7.7	26.0	/	/	Y
13	7.8	25.7	/	/	Y
14	7.6	23.0	/	/	Y
15	7.6	23.2	/	/	Y
16	7.7	21.0	/	/	Y
17	7.6	23.6	/	/	Y
18	7.6	22.9	/	/	Y
19	7.6	24.6	/	/	Y
20	7.8	26.0	/	/	Y
21	7.8	24.9	/	/	Y
22	7.8	24.4	/	/	Y
23	7.7	25.7	/	/	Y
24	7.8	25.4	/	/	Y
25	7.6	28.3	/	/	Y
26	7.7	27.6	/	/	Y
27	7.7	24.3	/	/	Y
28	7.7	24.3	/	/	Y
29	7.8	24.5	/	/	Y
30	7.7	26.9	/	/	Y
31	7.5	25.2	/	/	Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

<p>ENTRY POINT</p> <p>A</p> <p>PWS ID 4100591</p> <p>OREGON CITY - SOUTH FORK W B</p> <p>Sample Period: <u>January 2023</u></p> <p align="right">Month/Year</p>
--

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Richard Cage

Signature: *Richard Cage*

Date: February 1, 2023

Phone # 503-657-5030