

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	24.7			Y
2	7.5	26.7			Y
3	7.8	23.7			Y
4	7.7	25.4			Y
5	7.7	25.4			Y
6	7.6	23.9			Y
7	7.5	25.5			Y
8	7.7	25.2			Y
9	7.8	27.2			Y
10	7.8	26.5			Y
11	7.8	22.8			Y
12	7.8	22.5			Y
13	7.8	24.9			Y
14	7.6	24			Y
15	7.6	24.8			Y
16	7.5	24.1			Y
17	7.7	23.8			Y
18	7.8	24			Y
19	7.8	24.3			Y
20	7.8	27			Y
21	7.7	25.9			Y
22	7.6	25.1			Y
23	7.8	23.2			Y
24	7.8	24.4			Y
25	7.8	24.3			Y
26	7.7	24.4			Y
27	7.6	24.1			Y
28	7.6	25			Y
29					
30					
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
<b>Sample Period:</b> <u>February 2023</u>
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during previous 5 months:** 1  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?** Y

<b>Reference</b>
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

**Print Name:** Richard M. Cage

**Signature:** *Richard M. Cage*

**Date:** 3/1/23

**Phone #** 503-657-5030