

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	26.9			Y
2	7.7	24.7			Y
3	7.8	24.7			Y
4	7.9	25.5			Y
5	7.8	25.4			Y
6	7.6	23.9			Y
7	7.7	26.3			Y
8	7.6	27			Y
9	7.7	26.7			Y
10	7.6	27			Y
11	7.9	23.8			Y
12	7.7	24			Y
13	7.5	23.5			Y
14	7.6	25.2			Y
15	7.6	23.2			Y
16	7.7	26.5			Y
17	7.8	22.9			Y
18	7.7	22.7			Y
19	7.7	24.9			Y
20	7.6	23.3			Y
21	7.7	24.2			Y
22	7.6	24.2			Y
23	7.6	26.5			Y
24	7.7	23.3			Y
25	7.8	22			Y
26	7.7	22.2			Y
27	7.7	23.1			Y
28	7.5	22.5			Y
29	7.5	22.1			Y
30	7.7	24			Y
31	7.6	24.3			Y

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: March 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage

Signature: _____

Date: April 3, 2023

Phone #: 503-657-5030

(No = N = Excursion) Total N's 0