

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	22.2			Y
2	7.7	23			Y
3	7.6	23			Y
4	7.5	22.7			Y
5	7.5	23			Y
6	7.6	22.1			Y
7	7.7	22			Y
8	7.7	23.7			Y
9	7.6	22			Y
10	7.6	20.8			Y
11	7.5	20.2			Y
12	7.5	20.8			Y
13	7.5	21.6			Y
14	7.7	22.2			Y
15	7.7	22.6			Y
16	7.7	23			Y
17	7.7	23.9			Y
18	7.6	23.6			Y
19	7.6	23.8			Y
20	7.5	23.2			Y
21	7.6	23			Y
22	7.7	24.2			Y
23	7.6	22.5			Y
24	7.7	21.8			Y
25	7.5	22.6			Y
26	7.6	21.6			Y
27	7.6	20.5			Y
28	7.6	21			Y
29	7.7	21			Y
30	7.9	20.5			Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>April 2023</u>
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Richard M. Cage
Signature: *Richard M. Cage*
Date: 5/1/23
Phone # 503-657-5030