Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	20.1			Y
2	7.6	21.1			Y
3	7.5	20.1			Y
4	7.7	21.7			Y
5	7.7	21.3			Y
6	7.7	23.3			Y
7	7.7	22			Y
8	7.7	22.9			Y
9	7.5	23.5			Y
10	7.5	21.1			Y
11	7.6	20.8			Y
12	7.7	21.7			Y
13	7.7	21.5			Y
14	7.6	23.5			Y
15	7.5	22.1			Y
16	7.7	22.2			Y
17	7.6	21.8			Y
18	7.7	21			Y
19	7.8	20.5			Y
20	7.8	21.5			Y
21	7.9	21.9			Y
22	7.6	20.8			Y
23	7.6	21.3			Y
24	7.6	20.2			Y
25	7.6	20.4			Y
26	7.8	23.7			Y
27	7.7	24.8			Y
28	7.7	24.1			Y
29	7.6	22.7			
30	7.5	23.9			
31	7.6	23.6			
(No = N = Excursion) Total N's				0	

<< Have minimums been met for this day

ENTRY POINT

A

PWS ID 4100591

OREGON CITY - SOUTH FORK W B

Sample Period: May 2023

Month/Year

Number of excursions* during this month: 0

(*Count the number of days when any WQP was less than the minimum required*)

Total excursions during previous 5 months: 0

(*Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative*)

Is system in compliance? Y

Reference

Minimum Water Quality Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage

Signature : Richard M Cage

Date: 6/1/23

Phone # 503-657-5030

Send this form to DWP within 10 days after end of sampling period

OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405