

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	26.1			Y
2	7.7	25.4			Y
3	7.6	24.6			Y
4	7.6	24.7			Y
5	7.6	23.7			Y
6	7.5	25.1			Y
7	7.6	24.9			Y
8	7.5	27.5			Y
9	7.6	22.9			Y
10	7.6	24.5			Y
11	7.5	23.4			Y
12	7.5	27			Y
13	7.5	26.5			Y
14	7.5	26.5			Y
15	7.5	28			Y
16	7.6	27.3			Y
17	7.7	27.6			Y
18	7.6	31.3			Y
19	7.5	28			Y
20	7.6	29			Y
21	7.6	28			Y
22	7.7	30.8			Y
23	7.6	29.2			Y
24	7.6	30.6			Y
25	7.6	28.6			Y
26	7.5	25.5			Y
27	7.5	30.6			Y
28	7.5	29.1			Y
29	7.5	28.6			
30	7.6	29.2			
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>June 2023</u>
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Richard M. Cage

Signature: *Richard M. Cage*

Date: July 2, 2023

Phone # 503-657-5030