

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	32.5			Y
2	7.6	32.1			Y
3	7.6	30.5			Y
4	7.5	30.3			Y
5	7.5	31.4			Y
6	7.5	30			Y
7	7.5	30			Y
8	7.5	30.5			Y
9	7.6	30.9			Y
10	7.6	30.5			Y
11	7.6	32.4			Y
12	7.7	31.1			Y
13	7.6	32			Y
14	7.6	31.9			Y
15	7.6	30.2			Y
16	7.7	32.5			Y
17	7.6	32.5			Y
18	7.6	31.7			Y
19	7.6	33.2			Y
20	7.6	32.7			Y
21	7.6	32.4			Y
22	7.7	32.4			Y
23	7.6	30.5			Y
24	7.7	34.3			Y
25	7.6	31.2			Y
26	7.6	31			Y
27	7.6	35.1			Y
28	7.7	32.6			Y
29	7.7	32.6			Y
30	7.6	31.7			Y
31	7.6	32.3			Y
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

<p><b>ENTRY POINT</b></p> <p><b>A</b></p> <p><b>PWS ID 4100591</b></p> <p><b>OREGON CITY - SOUTH FORK W B</b></p> <p>Sample Period: <u>July 2023</u></p> <p align="right">Month/Year</p>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

<b>Reference</b>	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Richard M. Cage

Signature: *Richard M. Cage*

Date: 8/1/23

Phone #: 503-657-5030

Send this form to DWP within 10 days after end of sampling period  
 OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405