

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	32.1			Y
2	7.5	31.9			Y
3	7.6	31.7			Y
4	7.6	32.2			Y
5	7.6	32.8			Y
6	7.6	31.7			Y
7	7.7	33			Y
8	7.6	33.6			Y
9	7.5	33			Y
10	7.5	33.5			Y
11	7.6	31.4			Y
12	7.7	31.7			Y
13	7.7	32.1			Y
14	7.5	33.3			Y
15	7.6	31.2			Y
16	7.6	31			Y
17	7.6	31.7			Y
18	7.6	31.9			Y
19	7.6	31.6			Y
20	7.7	32.5			Y
21	7.7	34.1			Y
22	7.6	31.7			Y
23	7.6	31.5			Y
24	7.8	33.6			Y
25	7.7	31.7			Y
26	7.7	31.6			Y
27	7.7	32			Y
28	7.7	31.8			Y
29	7.6	32.2			Y
30	7.5	32.6			Y
31	7.5	34.3			Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: August 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference

Minimum Water Quality Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage

Signature: *Richard M. Cage*

Date: 9/5/23

Phone #: 503-657-5030