

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	33.5			Y
2	7.6	33.4			Y
3	7.7	32.9			Y
4	7.6	34.3			Y
5	7.6	34.1			Y
6	7.6	31.3			Y
7	7.6	32.2			Y
8	7.7	32.3			Y
9	7.6	32			Y
10	7.6	31.4			Y
11	7.6	31.6			Y
12	7.6	33			Y
13	7.5	34			Y
14	7.6	33.8			Y
15	7.6	31.8			Y
16	7.6	31.3			Y
17	7.6	29.9			Y
18	7.6	32			Y
19	7.6	30.6			Y
20	7.6	33			Y
21	7.6	31.4			Y
22	7.5	32.7			Y
23	7.7	31.1			Y
24	7.6	34.2			Y
25	7.6	32.9			Y
26	7.5	33.9			Y
27	7.6	30.8			Y
28	7.5	32.3			Y
29	7.7	31.5			Y
30	7.6	32.3			Y
31					
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

**ENTRY POINT**  
**A**  
**PWS ID 4100591**  
**OREGON CITY - SOUTH FORK W B**  
Sample Period: September 2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

**Reference**  
Minimum Water Quality  
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage  
Signature: *Richard M. Cage*  
Date: 10/2/23  
Phone #: 503-657-5030

Send this form to DWP within 10 days after end of sampling period  
OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405