

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	31.8			Y
2	7.6	31			Y
3	7.5	30.4			Y
4	7.7	27.8			Y
5	7.6	31.3			Y
6	7.6	31.3			Y
7	7.6	29.9			Y
8	7.7	30.2			Y
9	7.5	39.7			Y
10	7.5	35.3			Y
11	7.7	34.2			Y
12	7.7	31.4			Y
13	7.6	30.7			Y
14	7.7	29.2			Y
15	7.7	28.9			Y
16	7.6	27.3			Y
17	7.5	31.4			Y
18	7.7	27.2			Y
19	7.6	27.8			Y
20	7.7	29.8			Y
21	7.6	29.2			Y
22	7.7	29.7			Y
23	7.7	31.8			Y
24	7.6	33.1			Y
25	7.5	30.4			Y
26	7.6	29.7			Y
27	7.8	30.4			Y
28	7.8	29			Y
29	7.8	28.6			Y
30	7.6	30.8			Y
31	7.6	27.5			
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>October 2023</u>
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference	
Minimum Water Quality Parameters as set by State:	
pH <table border="1"><tr><td>7.5</td></tr></table>	7.5
7.5	
Alk <table border="1"><tr><td>20.0</td></tr></table>	20.0
20.0	

Print Name: Richard M. Cage

Signature: *Richard M. Cage*

Date: 11/6/23

Phone # 503-657-5030