

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	29.3			Y
2	7.7	26.8			Y
3	7.7	27.3			Y
4	7.8	21			Y
5	7.6	22.6			Y
6	7.5	24.2			Y
7	7.6	24.2			Y
8	7.6	20.5			Y
9	7.8	22.1			Y
10	7.9	23.9			Y
11	7.7	24			Y
12	7.6	24.2			Y
13	7.6	23.1			Y
14	7.6	21.7			Y
15	7.7	21.6			Y
16	7.8	25.5			Y
17	7.6	21.3			Y
18	7.6	23.5			Y
19	7.6	25.4			Y
20	7.5	24.2			Y
21	7.6	24.8			Y
22	7.7	24.8			Y
23	7.7	24.5			Y
24	7.6	26			Y
25	7.6	28			Y
26	7.6	25.6			Y
27	7.5	27.8			Y
28	7.6	25.5			Y
29	7.6	25.1			Y
30	7.6	24.3			Y
31	7.6	23.3			Y
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

<p><b>ENTRY POINT</b> <b>A</b> <b>PWS ID 4100591</b> <b>OREGON CITY - SOUTH FORK W B</b> Sample Period: <u>December 2023</u> Month/Year</p>
---

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

<b>Reference</b>	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Richard M. Cage  
Signature: *Richard M. Cage*  
Date: January 2, 2024  
Phone #: 503-657-5030