

**OHA Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.6	30.0			Y
2	7.6	26.6			Y
3	7.5	25.0			Y
4	7.6	25.8			Y
5	7.6	26.4			Y
6	7.6	25.6			Y
7	7.7	25.0			Y
8	7.6	22.6			Y
9	7.5	24.2			Y
10	7.5	22.0			Y
11	7.7	22.5			Y
12	7.7	24.7			Y
13	7.7	22.8			Y
14	7.7	23.8			Y
15	7.7	25.1			Y
16	7.6	23.6			Y
17	7.6	24.1			Y
18	7.6	20.5			Y
19	7.5	20.2			Y
20	7.6	23.0			Y
21	7.8	22.7			Y
22	7.7	21.6			Y
23	7.5	23.1			Y
24	7.7	20.9			Y
25	7.7	23.0			Y
26	7.8	22.0			Y
27	7.7	22.4			Y
28	7.7	20.3			Y
29	7.8	23.4			Y
30	7.5	24.1			Y
31	7.6	25.8			Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>January 2024</u>
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Richard Cage

Signature: *Richard Cage*

Date: February 1, 2024

Phone #: 503-657-5030