

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	24.8	/	/	Y
2	7.7	20	/	/	Y
3	7.9	22.4	/	/	Y
4	7.7	22.9	/	/	Y
5	7.7	24.3	/	/	Y
6	7.6	22.3	/	/	Y
7	7.6	23.9	/	/	Y
8	7.6	24.7	/	/	Y
9	7.7	24.2	/	/	Y
10	7.7	22	/	/	Y
11	7.8	23.9	/	/	Y
12	7.7	24.4	/	/	Y
13	7.6	25.6	/	/	Y
14	7.5	25.3	/	/	Y
15	7.5	24.5	/	/	Y
16	7.8	27.5	/	/	Y
17	7.8	22.1	/	/	Y
18	7.7	22.3	/	/	Y
19	7.6	23.5	/	/	Y
20	7.7	22.9	/	/	Y
21	7.5	23.1	/	/	Y
22	7.5	24.4	/	/	Y
23	7.6	24.2	/	/	Y
24	7.7	22.5	/	/	Y
25	7.7	25.4	/	/	Y
26	7.8	24.1	/	/	Y
27	7.5	22.6	/	/	Y
28	7.5	24.9	/	/	Y
29	7.7	23.6	/	/	
30			/	/	
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

**ENTRY POINT**  
**A**  
**PWS ID 4100591**  
**OREGON CITY - SOUTH FORK W B**  
Sample Period: February 2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

**Reference**  
Minimum Water Quality  
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage  
Signature: *Richard M. Cage*  
Date: 3/4/24  
Phone #: 503-657-5030

Send this form to DWP within 10 days after end of sampling period  
OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405