

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	22			Y
2	7.7	25.3			Y
3	7.7	24.5			Y
4	7.6	21.2			Y
5	7.6	24.8			Y
6	7.7	21			Y
7	7.5	25.8			Y
8	7.9	24.4			Y
9	7.9	23.3			Y
10	7.8	24.2			Y
11	7.6	25.4			Y
12	7.7	26.1			Y
13	7.8	23.6			Y
14	7.8	26.3			Y
15	7.9	22.5			Y
16	7.7	22.6			Y
17	7.7	24.8			Y
18	7.6	25.5			Y
19	7.5	24.4			Y
20	7.6	23.3			Y
21	7.6	24			Y
22	7.6	21.7			Y
23	7.7	21.8			Y
24	7.7	24.6			Y
25	7.6	24			Y
26	7.5	21.8			Y
27	7.6	21.4			Y
28	7.6	20.1			Y
29	7.7	22.1			Y
30	7.7	24.3			Y
31	7.6	21.8			Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>March 2024</u>
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Richard M. Cage

Signature: *Richard M. Cage*

Date: 4/1/24

Phone #: 503-657-5030

Send this form to DWP within 10 days after end of sampling period
OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405