

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	22.6			Y
2	7.7	25.3			Y
3	7.6	21.8			Y
4	7.7	21.2			Y
5	7.7	22.5			Y
6	7.62	20.2			Y
7	7.5	24.1			Y
8	7.7	21.6			Y
9	7.7	23.2			Y
10	7.7	23			Y
11	7.7	21			Y
12	7.7	21.8			Y
13	7.6	22			Y
14	7.7	23.3			Y
15	7.7	22			Y
16	7.6	21.4			Y
17	7.7	22.2			Y
18	7.7	22.9			Y
19	7.6	22			Y
20	7.7	26			Y
21	7.7	23.9			Y
22	7.7	24.8			Y
23	7.8	24			Y
24	7.7	22.9			Y
25	7.8	24.4			Y
26	7.7	23			Y
27	7.7	23			Y
28	7.7	22.7			Y
29	7.7	23.2			Y
30	7.7	24.3			Y
31	7.5	24.4			Y
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
<b>Sample Period:</b> <u>May 2024</u>
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?** Y

<b>Reference</b>
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

**Print Name:** Richard M. Cage  
**Signature:** *Richard M. Cage*  
**Date:** June 5, 2024  
**Phone #** 503-657-5030

Send this form to DWP within 10 days after end of sampling period  
 OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405