

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	31			Y
2	7.7	30.4			Y
3	7.8	31.5			Y
4	7.7	29.4			Y
5	7.7	32.3			Y
6	7.7	31.2			Y
7	7.6	32.3			Y
8	7.6	31.3			Y
9	7.6	31.1			Y
10	7.6	32.2			Y
11	7.7	29.2			Y
12	7.7	29.7			Y
13	7.6	29.2			Y
14	7.7	29.7			Y
15	7.7	31.1			Y
16	7.6	30.1			Y
17	7.6	31.1			Y
18	7.6	31.2			Y
19	7.6	31.7			Y
20	7.5	29.7			Y
21	7.6	29.7			Y
22	7.7	32			Y
23	7.7	30.8			Y
24	7.7	31.7			Y
25	7.8	33.4			Y
26	7.7	31			Y
27	7.7	33.6			Y
28	7.7	33.3			Y
29	7.7	35			Y
30	7.7	31.3			Y
31	7.7	30.5			Y

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
Sample Period: <u>July 2024</u>
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

<b>Reference</b>
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Richard M. Cage  
Signature: *Richard M. Cage*  
Date: August 1, 2024  
Phone #: 503-657-5030

(No = N = Excursion) Total N's 0