

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	31.1			Y
2	7.6	30.2			Y
3	7.7	31.4			Y
4	7.7	30.5			Y
5	7.6	32.1			Y
6	7.6	31.4			Y
7	7.7	30.6			Y
8	7.6	31.3			Y
9	7.6	31.1			Y
10	7.6	31.5			Y
11	7.6	30.2			Y
12	7.7	30			Y
13	7.7	32.4			Y
14	7.6	33.4			Y
15	7.6	33			Y
16	7.7	34			Y
17	7.7	33			Y
18	7.8	31.5			Y
19	7.6	32			Y
20	7.6	33.4			Y
21	7.7	30.3			Y
22	7.7	30.7			Y
23	7.7	32.3			Y
24	7.6	32.5			Y
25	7.7	30.8			Y
26	7.8	33.5			Y
27	7.6	31.8			Y
28	7.7	31.1			Y
29	7.7	34			Y
30	7.7	32			Y
31	7.7	32			Y
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

<p><b>ENTRY POINT</b> <b>A</b> <b>PWS ID 4100591</b> <b>OREGON CITY - SOUTH FORK W B</b> Sample Period: <u>August 2024</u> Month/Year</p>
---

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

<b>Reference</b>	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Richard M. Cage  
Signature: *Richard M. Cage*  
Date: September 3, 2024  
Phone #: 503-657-5030