

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|---------------------------------------|-----|------|------|------|-----|
| 1 | 7.7 | 32.4 | | | Y |
| 2 | 7.7 | 32.7 | | | Y |
| 3 | 7.7 | 36 | | | Y |
| 4 | 7.7 | 33 | | | Y |
| 5 | 7.7 | 33.2 | | | Y |
| 6 | 7.6 | 32.1 | | | Y |
| 7 | 7.6 | 33 | | | Y |
| 8 | 7.7 | 33 | | | Y |
| 9 | 7.7 | 33 | | | Y |
| 10 | 7.8 | 34.1 | | | Y |
| 11 | 7.8 | 34 | | | Y |
| 12 | 7.7 | 34 | | | Y |
| 13 | 7.7 | 33.8 | | | Y |
| 14 | 7.7 | 32.3 | | | Y |
| 15 | 7.8 | 27 | | | Y |
| 16 | 7.7 | 32.2 | | | Y |
| 17 | 7.7 | 32 | | | Y |
| 18 | 7.6 | 28.4 | | | Y |
| 19 | 7.6 | 33 | | | Y |
| 20 | 7.7 | 32 | | | Y |
| 21 | 7.7 | 30.3 | | | Y |
| 22 | 7.8 | 30.7 | | | Y |
| 23 | 7.7 | 33 | | | Y |
| 24 | 7.6 | 30.9 | | | Y |
| 25 | 7.6 | 35.2 | | | Y |
| 26 | 7.6 | 30.5 | | | Y |
| 27 | 7.7 | 31.3 | | | Y |
| 28 | 7.7 | 31.5 | | | Y |
| 29 | 7.7 | 30.7 | | | Y |
| 30 | 7.7 | 31.5 | | | Y |
| (No = N = Excursion) Total N's | | | | | 0 |

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: Sept 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? **Y**

Reference
Minimum Water Quality
Parameters as set by State:

| | |
|-----|------|
| pH | 7.5 |
| Alk | 20.0 |

Print Name: Richard M. Cage
Signature: *Richard M. Cage*
Date: 10/1/24
Phone #: 503-657-5030