

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	32.1			Y
2	7.6	32.3			Y
3	7.7	31.9			Y
4	7.6	33.3			Y
5	7.6	31.5			Y
6	7.7	31.2			Y
7	7.7	30.7			Y
8	7.6	31.7			Y
9	7.6	32.3			Y
10	7.7	33			Y
11	7.7	33.3			Y
12	7.7	32.3			Y
13	7.7	33.3			Y
14	7.6	32.1			Y
15	7.7	33.7			Y
16	7.6	33			Y
17	7.6	31.8			Y
18	7.7	33.2			Y
19	7.7	31.8			Y
20	7.8	32.5			Y
21	7.7	30.4			Y
22	7.6	31			Y
23	7.7	31.5			Y
24	7.6	31.2			Y
25	7.7	31.3			Y
26	7.7	31.7			Y
27	7.6	31.8			Y
28	7.6	30.2			Y
29	7.6	32.1			Y
30	7.6	30.4			Y
31	7.6	31.7			Y

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>October 2024</u>
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality
Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Richard M. Cage

Signature: *Richard M. Cage*

Date: November 4, 2024

Phone # 503-657-5030

(No = N = Excursion) Total N's 0