

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	30.6	/	/	Y
2	7.7	31.6	/	/	Y
3	7.5	25.2	/	/	Y
4	7.6	21.3	/	/	Y
5	7.6	25.5	/	/	Y
6	7.6	23.8	/	/	Y
7	7.6	25.1	/	/	Y
8	7.7	27.8	/	/	Y
9	7.7	28.5	/	/	Y
10	7.7	25.6	/	/	Y
11	7.6	27.4	/	/	Y
12	7.7	29.5	/	/	Y
13	7.7	28	/	/	Y
14	7.7	27	/	/	Y
15	7.6	21.5	/	/	Y
16	7.6	23.7	/	/	Y
17	7.7	22.6	/	/	Y
18	7.6	22.1	/	/	Y
19	7.5	20.8	/	/	Y
20	7.6	24.1	/	/	Y
21	7.6	21.4	/	/	Y
22	7.5	21	/	/	Y
23	7.6	26.4	/	/	Y
24	7.6	24.2	/	/	Y
25	7.7	24.1	/	/	Y
26	7.7	23.4	/	/	Y
27	7.7	23.7	/	/	Y
28	7.8	24	/	/	Y
29	7.8	23.7	/	/	Y
30	7.7	24.1	/	/	Y
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
<b>Sample Period:</b> <u>Nov 2024</u>
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Is system in compliance?** Y

<b>Reference</b>
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

**Print Name:** Richard M. Cage

**Signature:** *Richard M. Cage*

**Date:** 12/2/24

**Phone #** 503-657-5030