

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	25.6			Y
2	7.7	26.4			Y
3	7.7	27.9			Y
4	7.8	25.5			Y
5	7.9	28			Y
6	7.9	27.1			Y
7	7.8	27.9			Y
8	7.7	27.6			Y
9	7.7	24.9			Y
10	7.8	27.8			Y
11	7.8	24.2			Y
12	7.7	26			Y
13	7.7	26			Y
14	7.6	23.7			Y
15	7.8	22			Y
16	7.7	25.9			Y
17	7.8	24.7			Y
18	7.7	24.6			Y
19	7.6	23.2			Y
20	7.7	22			Y
21	7.8	22.8			Y
22	7.7	23.1			Y
23	7.7	23.2			Y
24	7.6	21.8			Y
25	7.6	21.4			Y
26	7.5	21			Y
27	7.6	21			Y
28	7.6	20			Y
29	8	23			Y
30	7.8	25.5			Y
31	7.6	20.8			Y
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

<p><b>ENTRY POINT</b> <b>A</b> <b>PWS ID 4100591</b> <b>OREGON CITY - SOUTH FORK W B</b> Sample Period: <u>December 2024</u> Month/Year</p>
---

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

<b>Reference</b>	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Richard M. Cage  
Signature: *Richard M. Cage*  
Date: January 6, 2025  
Phone #: 503-657-5030