

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	20.8	/	/	Y
2	7.8	22.7	/	/	Y
3	7.8	23.8	/	/	Y
4	7.8	23.2	/	/	Y
5	7.7	22.1	/	/	Y
6	7.7	22	/	/	Y
7	7.9	24.9	/	/	Y
8	8.1	22.4	/	/	Y
9	7.9	25.3	/	/	Y
10	8	25.1	/	/	Y
11	7.6	23	/	/	Y
12	7.8	24.7	/	/	Y
13	7.8	23.6	/	/	Y
14	7.9	25.5	/	/	Y
15	7.8	24.2	/	/	Y
16	7.8	26.1	/	/	Y
17	7.8	23.9	/	/	Y
18	7.9	24.8	/	/	Y
19	7.7	23.5	/	/	Y
20	7.8	25.8	/	/	Y
21	7.9	25.7	/	/	Y
22	7.8	25.8	/	/	Y
23	7.8	27.4	/	/	Y
24	7.8	25.7	/	/	Y
25	7.8	26.7	/	/	Y
26	7.7	25.8	/	/	Y
27	7.9	26.1	/	/	Y
28	7.8	27.8	/	/	Y
29	7.8	27.4	/	/	Y
30	7.7	27.8	/	/	Y
31	7.8	27.6	/	/	Y

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>January 2025</u>
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Richard M. Cage
 Signature: *Richard M. Cage*
 Date: 2/3/25
 Phone #: 503-657-5030

(No = N = Excursion) Total N's 0

Send this form to DWP within 10 days after end of sampling period
 OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405