

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	21.3			Y
2	7.8	23.5			Y
3	7.6	24.9			Y
4	7.7	22.9			Y
5	7.8	22.6			Y
6	7.8	23.5			Y
7	7.7	22.7			Y
8	7.9	23.6			Y
9	7.7	24.4			Y
10	7.7	24.3			Y
11	7.7	25.8			Y
12	7.9	26.7			Y
13	7.8	23.5			Y
14	7.8	23.8			Y
15	7.9	23.7			Y
16	7.7	23.3			Y
17	7.8	22.4			Y
18	7.6	22			Y
19	7.6	24.3			Y
20	7.8	23			Y
21	7.7	23			Y
22	7.7	22.4			Y
23	7.6	26			Y
24	7.6	22.3			Y
25	7.7	21.9			Y
26	7.9	20.4			Y
27	7.9	21			Y
28	7.9	21.4			Y
29	7.9	22.4			Y
30	7.8	21.1			Y
31	7.8	22.3			Y

<< Have minimums
been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
 Sample Period: March 2025
 Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y


Reference
 Minimum Water Quality
 Parameters as set by State:

 pH

7.5

 Alk

20.0

Print Name: Richard M. Cage
 Signature : 
 Date: April 2, 2025
 Phone # 503-657-5030

(No = N = Excursion) Total N's 0

Send this form to DWP within 10 days after end of sampling period
 OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405