

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	23.9			Y
2	7.6	21.4			Y
3	7.8	23			Y
4	7.8	23.3			Y
5	7.8	22.5			Y
6	7.7	23.5			Y
7	7.6	21.4			Y
8	7.8	24.1			Y
9	7.8	21.1			Y
10	7.8	22			Y
11	7.8	21			Y
12	7.8	21			Y
13	7.8	21.9			Y
14	7.7	22.4			Y
15	7.8	21.9			Y
16	7.8	22.8			Y
17	7.9	23.4			Y
18	7.8	25			Y
19	7.7	24.4			Y
20	7.8	22.8			Y
21	7.7	23.1			Y
22	7.6	22.6			Y
23	7.9	25.1			Y
24	7.8	23.4			Y
25	7.8	22.2			Y
26	7.9	24			Y
27	7.8	23.1			Y
28	7.7	21.6			Y
29	7.5	22.6			Y
30	7.8	23.1			Y
(No = N = Excursion) Total N's					0

<< Have minimums
been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: April 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
Minimum Water Quality
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage
Signature: 
Date: May 1, 2025
Phone #: 503-657-5030

Send this form to DWP within 10 days after end of sampling period
OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405