

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	26.9			Y
2	7.8	24.7			Y
3	7.8	24.9			Y
4	7.7	22.7			Y
5	7.6	26			Y
6	7.8	24.1			Y
7	7.8	22.7			Y
8	7.7	25.5			Y
9	7.7	26.6			Y
10	7.7	27.2			Y
11	7.7	25.1			Y
12	7.7	21.1			Y
13	7.7	26.3			Y
14	7.7	26.5			Y
15	7.6	26.4			Y
16	7.6	26.4			Y
17	7.7	29.1			Y
18	7.6	25.8			Y
19	7.7	25.9			Y
20	7.7	28.9			Y
21	7.8	25.5			Y
22	7.6	23.8			Y
23	7.7	24.2			Y
24	7.7	22.5			Y
25	7.7	27			Y
26	7.7	23.1			Y
27	7.8	25.5			Y
28	7.6	26.2			Y
29	7.7	28.3			Y
30	7.6	26.1			Y
31	7.6	25.5			Y

<< Have minimums
been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
 Sample Period: May 2025
 Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference
 Minimum Water Quality
 Parameters as set by State:


 pH

7.5

 Alk

20.0

Print Name: Richard M. Cage

Signature : 

Date: June 3, 2025

Phone # 503-657-5030

(No = N = Excursion) Total N's

0

Send this form to DWP within 10 days after end of sampling period

OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405