

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	25.8			Y
2	7.7	25.2			Y
3	7.6	25.5			Y
4	7.6	28.5			Y
5	7.7	28.2			Y
6	7.6	28.7			Y
7	7.6	28.3			Y
8	7.6	28.5			Y
9	7.6	29.7			Y
10	7.6	29.1			Y
11	7.7	28.1			Y
12	7.7	30.8			Y
13	7.7	30.7			Y
14	7.8	32.9			Y
15	7.7	31.5			Y
16	7.7	30			Y
17	7.6	31			Y
18	7.7	31.5			Y
19	7.6	28.2			Y
20	7.8	31.7			Y
21	7.7	30.7			Y
22	7.7	31			Y
23	7.7	31.2			Y
24	7.6	32.8			Y
25	7.7	31.2			Y
26	7.7	32.6			Y
27	7.8	32.1			Y
28	7.7	29.8			Y
29	7.7	34.5			Y
30	7.6	30.1			Y
(No = N = Excursion) Total N's					0

<< Have minimums
been met for this day

ENTRY POINT	
A	
PWS ID 4100591	
OREGON CITY - SOUTH FORK W B	
Sample Period:	June 2025
	Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Richard M. Cage
Signature : *Richard M. Cage*
Date: July 1, 2025
Phone # 503-657-5030

Send this form to DWP within 10 days after end of sampling period
OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405