

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	32.2			Y
2	7.7	31.3			Y
3	7.6	31.4			Y
4	7.6	30.1			Y
5	7.7	29.6			Y
6	7.6	30.9			Y
7	7.6	30.5			Y
8	7.7	33.3			Y
9	7.6	33.3			Y
10	7.6	29.3			Y
11	7.6	29.6			Y
12	7.6	30.7			Y
13	7.6	31.3			Y
14	7.6	30.7			Y
15	7.6	31.0			Y
16	7.6	34.0			Y
17	7.6	32.4			Y
18	7.6	29.2			Y
19	7.6	30.1			Y
20	7.6	30.3			Y
21	7.6	29.7			Y
22	7.7	32.9			Y
23	7.6	30.7			Y
24	7.6	29.3			Y
25	7.6	34.0			Y
26	7.6	32.0			Y
27	7.6	30.4			Y
28	7.7	30.7			Y
29	7.6	31.9			Y
30	7.7	30.3			Y
31	7.5	30.8			Y

<< Have minimums  
been met for this day

<b>ENTRY POINT</b>	
<b>A</b>	
<b>PWS ID 4100591</b>	
<b>OREGON CITY - SOUTH FORK W B</b>	
Sample Period:	July 2025
	Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required )

Total excursions during previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

Is system in compliance? Y

<b>Reference</b>	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Richard M. Cage  
Signature : *Richard M. Cage*  
Date: August 5, 2025  
Phone # 503-657-5030

(No = N = Excursion) Total N's 0

Send this form to DWP within 10 days after end of sampling period  
OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405