

Water Quality Parameter Monitoring Form **Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	31.1			Y
2	7.7	31.6			Y
3	7.6	30.5			Y
4	7.7	30.9			Y
5	7.6	33			Y
6	7.7	33.9			Y
7	7.6	31.3			Y
8	7.7	31			Y
9	7.7	30			Y
10	7.6	31.8			Y
11	7.6	33.6			Y
12	7.6	34.2			Y
13	7.6	33.3			Y
14	7.8	33.3			Y
15	7.7	33.5			Y
16	7.6	31.1			Y
17	7.7	32.8			Y
18	7.7	32.6			Y
19	7.7	35.3			Y
20	7.6	34.5			Y
21	7.6	31.7			Y
22	7.6	33.7			Y
23	7.6	32.1			Y
24	7.6	33.8			Y
25	7.6	34.4			Y
26	7.7	30.3			Y
27	7.8	35.2			Y
28	7.7	34.1			Y
29	7.7	31.8			Y
30	7.7	32.1			Y
31	7.7	31.6			Y
(No = N = Excursion) Total N's					0

<< Have minimums
been met for this day

ENTRY POINT

A

PWS ID 4100591

OREGON CITY - SOUTH FORK W B

Sample Period: August 2025

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference

Minimum Water Quality
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage

Signature : *Richard M. Cage*

Date: September 2, 2025

Phone # 503-657-5030

Send this form to DWP within 10 days after end of sampling period
 OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405