

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	34.4			Y
2	7.8	33.6			Y
3	7.7	33.9			Y
4	7.7	32.7			Y
5	7.7	34.4			Y
6	7.7	33.6			Y
7	7.6	30.6			Y
8	7.7	32.6			Y
9	7.8	32.9			Y
10	7.7	36.1			Y
11	7.6	32.2			Y
12	7.7	32.2			Y
13	7.6	32			Y
14	7.6	32.4			Y
15	7.6	31.9			Y
16	7.6	32.5			Y
17	7.6	33.3			Y
18	7.9	36			Y
19	7.7	31.1			Y
20	7.6	30.8			Y
21	7.5	33.9			Y
22	7.6	34.2			Y
23	7.6	35.1			Y
24	7.6	33.2			Y
25	7.8	32.9			Y
26	7.7	33.9			Y
27	7.7	34			Y
28	7.6	31			Y
29	7.6	32.9			Y
30	7.7	34.9			Y
(No = N = Excursion) Total N's					0

<< Have minimums
been met for this day

ENTRY POINT	
A	
PWS ID 4100591	
OREGON CITY - SOUTH FORK W B	
Sample Period:	September 2025
	Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference	
Minimum Water Quality Parameters as set by State:	
pH	7.5
Alk	20.0

Print Name: Richard M. Cage
Signature : *Richard M. Cage*
Date: October 2, 2025
Phone # 503-657-5030

Send this form to DWP within 10 days after end of sampling period
OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405