

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	35.1			Y
2	7.7	34			Y
3	7.6	32.2			Y
4	7.6	34.9			Y
5	7.6	33.6			Y
6	7.6	31.3			Y
7	7.6	33.1			Y
8	7.6	33			Y
9	7.7	31.2			Y
10	7.7	33.2			Y
11	7.6	31.8			Y
12	7.6	33.4			Y
13	7.5	32.6			Y
14	7.6	30			Y
15	7.6	31.2			Y
16	7.7	33.3			Y
17	7.7	33			Y
18	7.6	30.7			Y
19	7.6	33.8			Y
20	7.6	30.1			Y
21	7.6	31.9			Y
22	7.8	30.4			Y
23	7.8	34.7			Y
24	7.7	33.5			Y
25	7.5	31.6			Y
26	7.6	31.3			Y
27	7.7	32.7			Y
28	7.6	30.2			Y
29	7.5	27.2			Y
30	7.5	28.7			Y
31	7.7	28.1			Y
(No = N = Excursion) Total N's				0	

<< Have minimums
been met for this day

ENTRY POINT	
A	
PWS ID 4100591	
OREGON CITY - SOUTH FORK W B	
Sample Period:	October 2025
Month/Year	

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

Reference

Minimum Water Quality
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage
 Signature: Richard M. Cage
 Date: November 3, 2025
 Phone #: 503-657-5030

Send this form to DWP within 10 days after end of sampling period
 OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405