

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	27.4			Y
2	7.7	26.6			Y
3	7.7	29.6			Y
4	7.6	27.2			Y
5	7.6	27.9			Y
6	7.7	26.4			Y
7	7.8	27.5			Y
8	7.7	23.9			Y
9	7.7	24			Y
10	7.7	25.3			Y
11	7.9	24.2			Y
12	7.7	26.3			Y
13	7.7	26.2			Y
14	7.7	25.8			Y
15	7.8	27			Y
16	7.7	29.6			Y
17	7.8	27.5			Y
18	7.7	30.9			Y
19	7.7	27.5			Y
20	7.7	27.4			Y
21	7.8	29.8			Y
22	7.9	30.8			Y
23	7.7	30.3			Y
24	7.8	29.4			Y
25	7.7	27.7			Y
26	7.8	28.8			Y
27	7.6	30.1			Y
28	7.6	28.5			Y
29	7.8	28.7			Y
30	7.7	25.3			Y

(No = N = Excursion) Total N's

0

<< Have minimums  
been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
Sample Period: <u>November 2025</u>
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

**Reference**

Minimum Water Quality  
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage

Signature: Richard M. Cage

Date: December 3, 2025

Phone #: 503-657-5030

Send this form to DWP within 10 days after end of sampling period  
OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405