

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	26.7	/	/	Y
2	7.5	26.5	/	/	Y
3	7.7	29	/	/	Y
4	7.7	27.8	/	/	Y
5	7.6	26	/	/	Y
6	7.6	21	/	/	Y
7	7.6	21.5	/	/	Y
8	7.7	21.2	/	/	Y
9	7.7	21.4	/	/	Y
10	7.6	21.9	/	/	Y
11	7.7	21.4	/	/	Y
12	7.6	21	/	/	Y
13	7.7	22.2	/	/	Y
14	7.7	25.7	/	/	Y
15	8	23.4	/	/	Y
16	7.9	23.8	/	/	Y
17	7.6	23.3	/	/	Y
18	7.7	23.2	/	/	Y
19	7.5	33	/	/	Y
20	7.8	29	/	/	Y
21	7.7	20.5	/	/	Y
22	7.7	21.3	/	/	Y
23	7.8	23.3	/	/	Y
24	7.8	25.1	/	/	Y
25	8	21.6	/	/	Y
26	7.8	24.7	/	/	Y
27	7.9	24.7	/	/	Y
28	7.8	24.7	/	/	Y
29	7.8	23.4	/	/	Y
30	7.8	26	/	/	Y
31	8	26.5	/	/	Y
(No = N = Excursion) Total N's					0

<< Have minimums
been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: <u>December 2025</u>
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? **Y**

Reference
Minimum Water Quality Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Richard M. Cage
Signature: *Richard M. Cage*
Date: January 5, 2026
Phone # 503-657-5030

Send this form to DWP within 10 days after end of sampling period
OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405