

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.9	26.1	/	/	Y
2	7.7	26.2	/	/	Y
3	7.8	26.7	/	/	Y
4	7.9	27.5	/	/	Y
5	7.8	25.4	/	/	Y
6	7.8	26.3	/	/	Y
7	7.8	26.2	/	/	Y
8	7.9	25.1	/	/	Y
9	7.8	23.7	/	/	Y
10	7.7	23.5	/	/	Y
11	7.7	25	/	/	Y
12	7.9	27.8	/	/	Y
13	8.1	28	/	/	Y
14	7.9	26.8	/	/	Y
15	7.8	26.1	/	/	Y
16	8	28.3	/	/	Y
17	7.9	29.7	/	/	Y
18	8	27.1	/	/	Y
19	7.9	27.3	/	/	Y
20	8	29.9	/	/	Y
21	8	27.5	/	/	Y
22	7.8	26.2	/	/	Y
23	7.7	26.8	/	/	Y
24	7.9	26.3	/	/	Y
25	7.8	27.4	/	/	Y
26	8	26.6	/	/	Y
27	8	29.2	/	/	Y
28	7.9	27.5	/	/	Y
29	7.9	28.2	/	/	Y
30	7.9	28.8	/	/	Y
31	7.8	28.4	/	/	Y
<b>(No = N = Excursion) Total N's</b>					<b>0</b>

<< Have minimums been met for this day

<b>ENTRY POINT</b>
<b>A</b>
<b>PWS ID 4100591</b>
<b>OREGON CITY - SOUTH FORK W B</b>
Sample Period: <u>Jan-26</u>
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y

<b>Reference</b>
Minimum Water Quality
Parameters as set by State:
pH <u>7.5</u>
Alk <u>20.0</u>

Print Name: Richard M. Cage

Signature: *Richard M. Cage*

Date: 2/4/2026

Phone #: 503-657-5030

Send this form to DWP within 10 days after end of sampling period

OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405