

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.9	24.1	/	/	Y
2	7.8	24.1	/	/	Y
3	7.8	25.9	/	/	Y
4	7.8	23.1	/	/	Y
5	7.6	24.3	/	/	Y
6	7.7	23.7	/	/	Y
7	7.7	27.2	/	/	Y
8	7.7	24.3	/	/	Y
9	7.8	24.8	/	/	Y
10	7.7	23	/	/	Y
11	7.8	23.3	/	/	Y
12	7.7	22.4	/	/	Y
13	7.8	22.8	/	/	Y
14	7.9	20.1	/	/	Y
15	7.7	20	/	/	Y
16	7.9	24.1	/	/	Y
17	7.8	24.8	/	/	Y
18	7.8	22.5	/	/	Y
19	7.7	22.5	/	/	Y
20	8	25	/	/	Y
21	7.9	25.8	/	/	Y
22	7.9	24.2	/	/	Y
23	8	24.9	/	/	Y
24	7.8	23.8	/	/	Y
25	7.8	25.8	/	/	Y
26	7.8	24.9	/	/	Y
27	7.8	25.5	/	/	Y
28	7.7	24.4	/	/	Y
29	7.7	24.5	/	/	Y
30	7.7	24.2	/	/	Y
31	7.7	26.4	/	/	Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day

ENTRY POINT
A
PWS ID 4100591
OREGON CITY - SOUTH FORK W B
Sample Period: Mar-26
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? **Y**

Reference
Minimum Water Quality
Parameters as set by State:

pH	7.5
Alk	20.0

Print Name: Richard M. Cage

Signature: *Richard M. Cage*

Date: April 1, 2026

Phone #: 503-657-5030

Send this form to DWP within 10 days after end of sampling period

OHA Drinking Water Program. PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405