

# Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
4/1/2021	8.2	Y
4/2/2021	8.2	Y
4/3/2021	8.3	Y
4/4/2021	8.2	Y
4/5/2021	8.2	Y
4/6/2021	8.2	Y
4/7/2021	8.2	Y
4/8/2021	8.2	Y
4/9/2021	8.2	Y
4/10/2021	8.2	Y
4/11/2021	8.3	Y
4/12/2021	8.2	Y
4/13/2021	8.2	Y
4/14/2021	8.2	Y
4/15/2021	8.2	Y
4/16/2021	8.2	Y
4/17/2021	8.2	Y
4/18/2021	8.2	Y
4/19/2021	8.2	Y
4/20/2021	8.2	Y
4/21/2021	8.2	Y
4/22/2021	8.2	Y
4/23/2021	8.2	Y
4/24/2021	8.2	Y
4/25/2021	8.2	Y
4/26/2021	8.2	Y
4/27/2021	8.2	Y
4/28/2021	8.3	Y
4/29/2021	8.2	Y
4/30/2021	8.3	Y

County: Multnomah Agency: Region 1

**Entry Point  
EP-A**

**PWS ID: OR 4100657  
Portland Bureau of Water Works**

Month: **April 2021**

Sampling Period: **January to June 2021**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**  
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:
-----------------------------------------------------

<b>pH</b>	<b>8.0</b>
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 5/5/21

**Total No's: 0**