

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
11/1/2021	8.3	Y
11/2/2021	8.2	Y
11/3/2021	8.2	Y
11/4/2021	8.3	Y
11/5/2021	8.2	Y
11/6/2021	8.2	Y
11/7/2021	8.2	Y
11/8/2021	8.2	Y
11/9/2021	8.3	Y
11/10/2021	8.2	Y
11/11/2021	8.2	Y
11/12/2021	8.2	Y
11/13/2021	8.2	Y
11/14/2021	8.2	Y
11/15/2021	7.1	N
11/16/2021	100% Groundwater	
11/17/2021	8.0	Y
11/18/2021	8.2	Y
11/19/2021	8.3	Y
11/20/2021	8.2	Y
11/21/2021	8.2	Y
11/22/2021	8.2	Y
11/23/2021	8.2	Y
11/24/2021	8.2	Y
11/25/2021	8.2	Y
11/26/2021	8.2	Y
11/27/2021	8.3	Y
11/28/2021	8.3	Y
11/29/2021	8.2	Y
11/30/2021	8.2	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **November 2021**

Sampling Period: **July to December 2021**

Number of Excursions During this Month: **1**

Total Excursions During this Sampling Period: **1**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:

pH	8.0
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 12/9/21

Total No's: 1