

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
1/1/2022	8.3	Y
1/2/2022	8.2	Y
1/3/2022	8.3	Y
1/4/2022	8.3	Y
1/5/2022	8.3	Y
1/6/2022	8.3	Y
1/7/2022	8.3	Y
1/8/2022	8.3	Y
1/9/2022	8.2	Y
1/10/2022	8.2	Y
1/11/2022	8.2	Y
1/12/2022	8.2	Y
1/13/2022	8.3	Y
1/14/2022	8.3	Y
1/15/2022	8.3	Y
1/16/2022	8.3	Y
1/17/2022	8.3	Y
1/18/2022	8.3	Y
1/19/2022	8.3	Y
1/20/2022	8.3	Y
1/21/2022	8.3	Y
1/22/2022	8.3	Y
1/23/2022	8.3	Y
1/24/2022	8.3	Y
1/25/2022	8.3	Y
1/26/2022	8.3	Y
1/27/2022	8.3	Y
1/28/2022	8.4	Y
1/29/2022	8.3	Y
1/30/2022	8.3	Y
1/31/2022	8.3	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **January 2022**

Sampling Period: **January to June 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 2/9/22

Total No's: 0